

**Fw: Pineview dw monitoring**

Aaron Setran to: David Albright, Rich Campbell
Cc: Roger Yates, Corine Li

04/17/2012 09:46 AM

From: Aaron Setran/R9/USEPA/US
To: David Albright/R9/USEPA/US@EPA, Rich Campbell/R9/USEPA/US@EPA,
Cc: Roger Yates/R9/USEPA/US@EPA, Corine Li/R9/USEPA/US@EPA

David/Rich:

At the mtg last week in Carson City (regarding Pineview Estates) I became aware that there is no requirement for chlorination of the drinking water system for the public water supply at the subdivision. This is a bit unusual, and perhaps a bit unsafe given the problems with the injection wells at the site. There have been numerous coliform violations in the groundwater monitoring wells over the last 18 months.....the dw well is located near the leachfields, but pulls water from about a 500' depth. In addition, the current dw sampling requirements (see attachment below) only require monthly sampling for coliform, and only annual sampling for nitrate.....without exception, MCLs for nitrates in the ground water monitoring wells have been exceeded during the last 18 months.

It might be a good idea to have more frequent sampling for both coliform and nitrates from the dw while the problems with the wastewater injection wells are being addressed. There's a good chance that BIA will cover additional costs associated with increased sampling, but we may need to get a bit "pushy" about it first.

Aaron Carr Setran
U.S. EPA, Water Division
75 Hawthorne St.
San Francisco, CA 94105
(415) 972-3457

----- Forwarded by Aaron Setran/R9/USEPA/US on 04/17/2012 09:32 AM -----

From: Roger Yates/R9/USEPA/US
To: Aaron Setran/R9/USEPA/US@EPA
Date: 04/17/2012 09:23 AM
Subject: Re: Pineview dw monitoring



MonitoringScheduleReport-Pine View Estates-3200374---04-17-2012.PDF

USEPA Region 9 Drinking Water Office (WTR-6)
75 Hawthorne St.
San Francisco, CA 94105-3901
Telephone: (415) 972-3549

If not available leave message or if you need immediate response dial 00 and ask for a Tribal Drinking Water Team Member

Fax: (415) 947-3549
E-mail: yates.roger@epa.gov

Aaron Setran

Roger: Can you tell me which dw constituents ar...

04/17/2012 08:22:27 AM

From: Aaron Setran/R9/USEPA/US
To: Roger Yates/R9/USEPA/US@EPA

Date: 04/17/2012 08:22 AM
Subject: Pineview dw monitoring

Roger:

Can you tell me which dw constituents are monitored at Pineview Estates, and how often. Thanks, Aaron

Aaron Carr Setran
U.S. EPA, Water Division
75 Hawthorne St.
San Francisco, CA 94105
(415) 972-3457